

**Request for Proposals**  
**RFP- IT-2019-001**  
**Recently Asked Questions**

1. How are the data drop locations in the floor fed?

**As in is it a conduit home run to the IT closet or a pipe into the nearest ceiling space**

2. Are you looking to bid out the communications cabling and the electric cabling separately or together?

**Separately**

3. Are telephone and data lines to be on shared or separate patch panels?

**Shared**

4. At drop locations, are we running a single drop or is it dependent on the required faceplate for the location? (Some place call for quad port face plates but only show a single cable home run)

**Depends on the required faceplate for the location**

5. For labeling, what is the expectation for a single location with multiple, drops? (Quad port with 2 voice and 2 data: 135a24Va, 135a24Vb, 135a24Da, 135a24Db)?

**For drops, we do not label voice and data with letters. We only indicate floor, patch panel number, patch panel port: 2-A-39 - 2nd floor, patch panel A, port 39.**